

**APPROVES THE INSTALLATION OF SIXTEEN FIRE HYDRANTS WITHIN THE CHESTERFIELD BLUE VALLEY SUBDIVISION LOCATED IN THE CITY OF CHESTERFIELD**

**WHEREAS**, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

**WHEREAS**, authorization of the placement of said fire hydrants requires a City ordinance.

**NOW THEREFORE BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:**

**Section 1.** The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

a. Five (5) fire hydrants on Premium Way:

1. 29.5 feet east of the centerline of Premium Way; 145.5 feet north of the centerline of Olive Street Road.
2. 29.5 feet east of the centerline of Premium Way; 668.5 feet north of the centerline of Olive Street Road.
3. 29.5 feet east of the centerline of Premium Way; 965 feet north of the centerline of Olive Street Road.
4. 29.5 feet east of the centerline of Premium Way; 386 feet south of the centerline of Olive Street Road.
5. 29.5 feet east of the centerline of Premium Way; 145.5 feet south of the centerline of Olive Street Road.

b. Eleven (11) fire hydrants on Outlet Boulevard:

1. 42 feet east of the centerline of Outlet Boulevard; 694 feet south of the centerline of Premium Way.
2. 42 feet east of the centerline of Outlet Boulevard; 154 feet north of the centerline of Premium Way.
3. 42 feet east of the centerline of Outlet Boulevard; 145 feet south of the centerline of Premium Way.
4. 42 feet east of the centerline of Outlet Boulevard; 448 feet south of the centerline of Premium Way.
5. 42 feet east of the centerline of Outlet Boulevard; 180 feet south of the centerline of Premium Way.
6. 42 feet east of the centerline of Outlet Boulevard; 522 feet north of the centerline of Olive Street Road.

7. 42 feet east of the centerline of Outlet Boulevard; 224 feet north of the centerline of Olive Street Road.
8. 41.5 feet east of the centerline of Outlet Boulevard; 383 feet south of the centerline of Premium Way.
9. 41.5 feet east of the centerline of Outlet Boulevard; 105 feet east of the centerline of Premium Way.
10. 41.5 feet east of the centerline of Outlet Boulevard; 216 feet west of the centerline of Premium Way.
11. 41.5 feet east of the centerline of Outlet Boulevard; 492.5 feet west of the centerline of Premium Way.

**Section 2.** The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid location.

**Section 3.** This Ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this \_\_\_\_\_ day of \_\_\_\_\_, 2013.

\_\_\_\_\_  
MAYOR

ATTEST:

\_\_\_\_\_  
CITY CLERK

FIRST READING HELD: _____
---------------------------

I, Thomas J. Vineyard, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 5th day of August, 2013, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 16 public fire hydrant(s) in Chesterfield Blue Valley (subdivision) as follows:

**Phase 1 –**

1. Premium Way – 29.5ft E of CL of Premium Way; 145.5ft N. of CL of Olive St. Rd
2. Premium Way – 29.5ft E of CL of Premium Way; 668.5ft N. of CL of Olive St. Rd
3. Premium Way – 29.5ft E of CL of Premium Way; 965ft N. of CL of Olive St. Rd
4. Premium Way – 29.5ft E of CL of Premium Way; 386ft S. of CL of Outlet Blvd
5. Premium Way – 29.5ft E of CL of Premium Way; 145.5ft N. of CL of Olive St. Rd
6. Outlet Blvd – 41.5ft E. Of CL of Outlet Blvd; 383ft S. of CL of Premium Way
7. Outlet Blvd – 41.5ft E. Of CL of Outlet Blvd; 105ft E. of CL of Premium Way
8. Outlet Blvd – 41.5ft E. Of CL of Outlet Blvd; 216ft W. of CL of Premium Way
9. Outlet Blvd – 41.5ft E. Of CL of Outlet Blvd; 492.5ft W. of CL of Premium Way

**Phase 2 –**

10. Outlet Blvd – 42ft East of CL of Outlet Blvd; 694ft S of CL of Premium Way
11. Outlet Blvd – 42ft East of CL of Outlet Blvd; 154ft N of CL of Premium Way
12. Outlet Blvd – 42ft East of CL of Outlet Blvd; 145ft S of CL of Premium Way
13. Outlet Blvd – 42ft East of CL of Outlet Blvd; 448ft S of CL of Premium Way
14. Outlet Blvd – 42ft East of CL of Outlet Blvd; 180ft S of CL of Premium Way
15. Outlet Blvd – 42ft East of CL of Outlet Blvd; 522ft N of CL of Olive St. Rd


16. Outlet Blvd – 42ft East of CL of Outlet Blvd; 224ft N of CL of Olive St. Rd

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for Chesterfield Blue Valley (subdivision) to be 3,000 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said 16 public fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 5th day of August, 2013.

  
FIRE CHIEF

